

# 安全评价报告信息网上公示

项目概况	项目名称	中国石油天然气股份有限公司甘肃张掖销售分公司临泽倪家营加油站安全现状评价报告		
	行业类别	石油加工业，化学原料、化学品及医药制造业	报告提交时间	2024.1.26
	项目简介	<p>中国石油天然气股份有限公司甘肃张掖销售分公司临泽倪家营加油站于 2001 年 05 月 22 日成立，位于甘肃省张掖市临泽县倪家营乡，张掖销售分公司法定代表人为李杰，加油站安全管理人员为苏新华，该加油站的危险化学品经营许可证有效期限为 2021 年 03 月 16 日至 2024 年 03 月 15 日。许可范围：汽油、柴油。</p> <p>该加油站设置直埋地下非承重卧式双层油罐 3 个，其中 1 个 30m<sup>3</sup>汽油罐、2 个 30m<sup>3</sup>柴油罐，总储量为 90m<sup>3</sup>，折合储量为 60m<sup>3</sup>(柴油罐容积折半计算)，根据《汽车加油加气加氢站技术标准》(GB50156-2021)第 3.0.9 条规定属于三级加油站。</p>		
安全评价项目参与人员	项目评价组长	张书杰	技术负责人	邹方永
	过程控制负责人	唐晓娟	报告编制人	张书杰
	报告审核人	王晓华	安全评价师	刘全进 李茂刚 臧怀壮 郭晓娟 曹旭辉
	注册安全工程师	张书杰、刘全进、唐晓娟、邹方永	技术专家及技术人员	——
评价活动主要信息	安全评价类型	现状评价		
	到现场开展评价工作人员	张书杰 曹旭辉		
	到现场开展评价工作时间及主要任务	2023.11.10 对现场进行勘验，并收集资料；2024.1.9 对现场问题进行了复查。		

现场照片





		 <p>The photograph shows an open electrical cabinet with several safety and identification labels. At the top, two blue labels read "先接地 再接管" (Ground first, then connect pipe) and "双确认 后卸油" (Double confirmation, then unload oil). Inside the cabinet, there are orange labels with "52MSI" and "52" written on them. Green labels indicate "-20℃" and "201号罐" (Tank 201). Other green labels show "0" and "0". The cabinet contains various electrical components, including a meter and some wiring.</p>
	备注及其他信息	无